

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 995

Dated: - 18/9/2026

It is certified that an inspection team headed by Sudesh Kumari (Sub. Divisional Engineer

(Name of Officers with designation) from Kharkhoda PHED

inspected the Buddha International Public School, V.P.O. Khurampur, Bah. Kkd Road
Kharkhoda Sonipat

(Name & Address of the school) on 16/9/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. T.O. 126 HR 18248 dated 13/8/2026

of State Water Testing Lab, Karnal (PHED Lab) certified that

the Buddha International Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 17/9/2027

Signature with Seal: Sub. Divisional Engineer

Name : Public Health Engineering S/O

Designation : Kharkhoda

Name & Address of the Office / Department :

To Buddha International Public School
V.P.O. Khurampur, Kharkhoda Bahadurgarh Road, District Sonipat
(Name & Address of the Institution) Haryana

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Memo No:- 4723

Date:- 14/08/2026

T0626HR18248

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : KNL/06549/8/2026 / Private Sender : BUDDHA INTERNATIONAL PUBLIC SCHOOL Location : , BUDDHA INTERNATIONAL PUBLIC SCHOOL Sample Description : Drinking Water Latitude / Longitude : 76.882968 / 28.825801			Sample Details		Date & Time	
			Collected By		YOGENDER DAHIYA	
			Collection Date		13/08/2026 at 12:16	
			Received at lab		13/08/2026 at 12:46	
			Analysis Start Date		13/08/2026	
			Analysis End Date		14/08/2026	
			Sample Quantity		1000 ml	
Test Result (As Per BIS 10500 :2012)						
S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used	
1	Turbidity	<1	1 NTU	5 NTU	IS 3025 (Part-10):1984 (RA 2022)	
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) :1984 (RA 2022)	
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) :1984 (RA 2018)	
4	Color	<5	5 Hazen Units	15 Hazen Units	IS 3025 (Part 4): 2021	
5	Total Dissolved Solids @ 180°C ± 2°C	150	500 mg/lit.	2000 mg/lit.	IS 3025 (Part-16) : 2023	
6	Total Hardness as CaCo3	100	200 mg/lit.	600 mg/lit.	IS 3025 (Part-21) : 2009 (RA 2023)	
7	Calcium (as Ca)	20	75 mg/lit.	200 mg/lit.	IS 3025 (Part-40) :1991 (RA 2023)	
8	Magnesium (as Mg)	12	30 mg/lit.	100 mg/lit.	IS 3025 (Part-46) (RA 2023)	
9	Total Alkalinity	110	200 mg/lit.	600 mg/lit.	IS 3025 (Part-23) : 1986 (RA 2019)	
10	Chloride (as Cl)	36	250 mg/lit.	1000 mg/lit.	IS 3025 (Part-32) :1988 (RA 2019)	
11	Sulphate as So4	10	200 mg/lit.	400 mg/lit.	USEPA-8051:2017	
12	Fluoride (as F)	0.210	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C	
13	Iron (as Fe)	0.02	1.0 mg/lit.	1.0 mg/lit.	USEPA-8008:2017	
14	Nitrate (as No3)	1.3	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO3 D	
15	pH @ 25°C	7.39	6.5 - 8.5	6.5 - 8.5	IS 3025 (Part-11) : 2022	

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED KARNAL Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

AMIT KUMAR, CHIEF CHEMIST
STATE WATER TESTING LABORATORY KARNAL
email:-chiefchemist.hr@phedharyana.gov.in